Planning Sub Committee 11th June 2018

ADDENDUM REPORT

UPDATE FOR CONSIDERATION AT PLANNING SUB-COMMITTEE Item No 8.

| Reference No: HGY/2016/0558 | Ward: White Hart Lane | |
|-----------------------------|-----------------------|--|
|-----------------------------|-----------------------|--|

Address: St John's Church and Hall, Acacia Avenue, London, N17 8LR

Proposal: Remodelling and extension to existing church. Demolition and replacement of existing hall on church site with new community facility / nursery. Proposed 22 new build residential units to church site and 10 new build residential units to Acacia Avenue site with a mix of 1, 2, 3, and 4 bedroom accommodation over 2 - 4 storeys.

1.0 LOCAL REPRESENTATIVES (AMENDED DRAWINGS following Listing)

- 1.1 The following were consulted:
 - 163 Neighbouring properties
 - 3 site notices were erected close to the site
 - Press Notice
- 1.2 The number of representations received from neighbours, local groups etc in response to notification and publicity of the application were as follows:

No of individual responses: Objecting: 4 Supporting: 0 Others: 0

- 1.5 The issues raised in representations that are material to the determination of the application are summarised as follows. All responses are in relation to Site B (Acacia Avenue).
 - Proposal too large and too close in relation to gardens between 350 White Hart Lane and Cambridge Road
 - Loss of privacy/overlooking/overshadowing
 - Out of place characte
- 5.4 The objections outlined above all relate to 'Site B', the Acacia Road site. This section of the proposal has not changed from that presented to The Planning Committee in June 2017 and considered in para 6.5.3 of the Planning Sub-Committee report. As such, there are no additional material considerations to consider.

2.0 AFFORDABLE HOUSING

1.1. Since the Planning Committees resolution to grant planning permission in June 2017, the affordable housing provision has been altered to reflect the direction of Housing Policy:

6 no. London Affordable Rent units / 21 hab rooms

- 1 x 1 bed
- 2 x 2 bed
- 2 x 3 bed
- 1 x 4 bed

Total 6 units

<u>11 no. (intermediate) London Living Rent / 30 hab rooms (such rents to be aligned with the London Living Rent benchmarks published by the Mayor of London)</u>

- 2 x studio
- 4 x 1 bed
- 5 x 3 bed

Total 11 units

- <u>15 no. Private / 43 hab rooms</u>
- 7 x 1 bed
- 4 x 2 bed
- 3 x 3 bed
- 1 x 4 bed

Total 15 units

Overall Total: 32

- 1.2. The Affordable rented element of the proposed affordable housing will be London Affordable Rent. This is one of the new affordable products that is being promoted by the Mayor of London. The rents of these units are broadly equivalent to social rents and sit at around 55% of market for one beds and lower than 55% for larger units.
- 1.3. The intermediate element of the proposed affordable housing will be London Living Rent. London Living Rent is one of the new affordable products that are being promoted by the Mayor of London. London Living Rent homes are for middle-income households who now rent and want to build up savings to buy a home. This can be either through shared ownership or outright purchase. Landlords are expected to encourage their tenants into home ownership within ten years.

- 1.4. The homes will be offered on tenancies of a minimum of three years. Tenants will be supported to save and given the option to buy their home on a shared ownership basis during their tenancy. They will also be given extra priority for other shared ownership homes across London.
- 1.5. Across London as a whole, the average monthly rent for a two-bedroom London Living Rent home is around two-thirds of the median market rent. To be eligible for a London Living Rent home, you must:
 - be renting in London
 - have a maximum household income of £60,000
 - be unable to currently buy a home (including through shared ownership) in your local area
- 1.6 This represents a split that is approximately 60% intermediate and 40% affordable rented housing. Given that the applicant is proposing affordable products which are at the most affordable end of the spectrum of affordable products and given the levels of shared ownership property delivered in the east of the borough this increase in rental provision is in accordance with The figures have been agreed with Haringey's Intermediate Housing Statement (2018). An additional affordable unit has also been provided since the previous Committee resolution, increasing the overall affordable housing provision to 53%.

UPDATE FOR CONSIDERATION AT PLANNING SUB-COMMITTEE Item No. 9

| Reference No: HGY/2017/3071 | Ward: Highgate | |
|---|----------------|--|
| Address: 65 & 67 North Road, London, N6 4BQ | | |
| Proposal: The demolition of existing buildings and the construction of a part single, part three storey building to provide 8 self-contained flats | | |

Public Notification

7 Additional objections following re-consultation on the 21st of May

- Impact on traffic and parking
- Overdevelopment of the site
- Out of character with the conservation area
- Detracts from the listed buildings
- Pedestrian safety
- Loss of privacy

OFFICER RESPONSE:

These issues have been highlighted previously and have been addressed in the Committee Report.

Seven emails were received from third parties requesting an extension to the latest consultation, dated 21st May (seeking 21 days instead of 14), however there is no statutory requirement to do so and there has been no material change in the proposal itself since the earlier re-consultation on the 25th of January 2018.

Appendix: Responses Summary (North Road)

| No. | Stakeholder | Question/Comment | Response |
|-----|----------------------|--|---|
| | | | |
| No. | EXTERNAL | | |
| 1. | London Fire Brigade: | 1. We note the non-standard approach to appliance access and the extended hose-laying distance proposed. As no exact dimensions have been provided, this response is based on the information available from the referral form. | As highlighted in section 6.65 of the Committee report, details in relation to access and swept paths has been provided. |
| | | 2. We are of the opinion that 100m to an inlet point of a dry rising fire main is not a suitable arrangement. This would require at least 10 lengths of hose to be laid out and charged with water before crews could use the dry riser. This is normally achieved with 2 lengths over 18m. The distance to carry equipment to the base of the stairs also exceeds the distance permitted by guidance. | The details show that it would be possible that a fire tender can access the front of the site and that it would be possible for a fire tender to access North Road and turn in order to exit in a forward gear. |
| | | 3. The requirement to provide appliance access appears to have been demonstrated via the appliance tracking plan but we would have concerns regarding the management and availability of this access route. It would be our usual expectation that the access road is hatched and parking controlled in order to ensure that the route is available at all material times and access to any provided fire mains should be within 18m. | In addition, the provision of dry risers to the front of each flatted entrance would allow for vehicle access to a pump appliance within 45m of all points within each dwelling. A domestic sprinkler system is also as part of the |
| | | 4. In light of the items discussed above, an automatic water suppression system may provide a measure of mitigation. Any proposed systems should fully comply with either BS | development. These issues raised are highlighted in section |

| No. | Stakeholder | Question/Comment | Response |
|-----|-----------------|---|--|
| | | 9251:2014, 'Fire sprinkler systems for domestic and residential occupancies. Code of practice.' or BS8458-1:2015, 'Fixed fire protection systems. Residential and domestic watermist systems. Code of practice for design and installation.'. The guidance provided in BS9991:2015 indicates that where a fire suppression system is provided then the distance between the appliance and any point within the house or flat may be up to 75m (instead of 45m), for the case where there is a floor more than 4.5 m above ground level. | 6.66 – 6.67 |
| | | 5. It would also be our usual expectation that a water hydrant be provided within 90m of any dry fire main inlets. | |
| | RESIDENT GROUPS | | |
| 2. | Highgate CAAC | Loss of green space | Highlighted in sections 6.11 – 6.16 |
| | | Impact on the conservation area | Highlighted in sections 6.30 – 6.37 |
| | | Impact on neighbouring listed buildings | Highlighted in sections 6.38 – 6.40 |
| | | Impact on Metropolitan Open Land | Highlighted in sections 6.13 – 6.15 |
| | | Impact on neighbouring amenity from use of terraces | Highlighted in sections 6.53 – 6.55 |
| | | Impact on access from delivery vans | Highlighted in section 6.59 & 6.67 |
| | | Intensification of vehicles | Highlighted in section 6.59 & 6.67 |
| | | Inadequate Fire Brigade access | These issues raised are highlighted in section 6.66 – 6.67 |

| No. | Stakeholder | Question/Comment | Response |
|-----|----------------------|--|---|
| 3. | The Highgate Society | Non-compliance with the Highgate Neighbourhood Plan | Demonstration of compliance with the HNP highlighted in sections 6.5, 6.11, 6.12, 6.35 & 6.72 |
| | | | Highlighted in sections 6.7 – 6.8 |
| | | Overdevelopment of the site | Highlighted in sections 6.74 – 6.76 |
| | | Lack of soft landscaping | Highlighted in sections 6.11 – 6.16 |
| | | Loss of garden land | Highlighted in sections 6.38 – 6.40 |
| | | Impact on neighbouring listed buildings | |
| | | | Highlighted in sections 6.60 – 6.68 |
| | | Concerns regarding access | Highlighted in sections 6.61 – 6.65 |
| | | Parking and congestion | Highlighted in sections 6.70 – 6.71 |
| | | Impact of refuse collection No disabled parking space | Amended drawings have shown a Disabled parking space as highlighted in section 6.65. |
| | | | Not a material consideration as highlighted in section 5.7 |
| | Right of way issues | Highlighted in sections 6.56 | |
| | | Highlighted in section 6.65 – 6.66 | |
| | | No daylighting study provided | Not a material consideration as highlighted in |
| | | Inadequate Fire Brigade access | section 5.7 |

| No. | Stakeholder | Question/Comment | Response |
|-----|---|--|-------------------------------------|
| | | No consultation prior to submission of application | |
| 4. | The Twentieth Century Society | Impact on conservation area | Highlighted in sections 6.30 – 6.37 |
| | | Impact on neighbouring listed buildings | Highlighted in sections 6.38 – 6.40 |
| 4. | LOCAL RESIDENTS | | |
| | Principle of the | Overdevelopment of the site | Highlighted in sections 6.7 – 6.8 |
| | development | No affordable housing provision Backland development | Highlighted in sections 6.9 - 6.10 |
| | | Loss of green space | Highlighted in sections 6.11 – 6.16 |
| | | | Highlighted in sections 6.11 – 6.16 |
| | Quality of accommodation | Concerns regarding housing mix / tenure | Highlighted in sections 6.45 – 6.50 |
| | | Poor standard of accommodation | |
| | Design / impact on the | Impact on neighbouring heritage assets | Highlighted in sections 6.30 – 6.40 |
| | conservation area and listed buildings | | Highlighted in sections 6.30 – 6.37 |
| | | Excessive volume of the proposed building | Highlighted in section 6.19 |
| | | | Highlighted in sections 6.21 – 6.29 |
| | Impact on neighboring | Overlooking and loss of privacy Noise and disturbance from increase in movements to and | Highlighted in sections 6.54 – 6.56 |

| No. | Stakeholder | Question/Comment | Response |
|-----|---|--|--|
| | amenity | from the site Loss of light Overbearing impact Light spillage from the development Impact on air quality | Highlighted in sections 6.56 Highlighted in sections 6.55 Highlighted in section 6.58 Highlighted in section 6.58 |
| | Traffic, Parking, Access and Sustainable Transport | Insufficient parking spaces Proposal does not comply with fire regulations Insufficient circulation space Impacts upon road and pedestrian safety Issues regarding refuse collection | Highlighted in sections 6.61 – 6.65 These issues raised are highlighted in section 6.66 – 6.67 Highlighted in section 6.65 Highlighted in sections 6.68 – 6.69 Highlighted in section 6.70 – 6.71 |
| | Trees and ecology | Ecological impact of the development Impact on trees Impact upon Metropolitan Open Land | Highlighted in section 6.77 – 6.78 Highlighted in section 6.72 – 6.76 Highlighted in sections 6.13 – 6.15 |