

Barrett Daliah

Subject: FW: 16-20 High Road, N22 6BX

From: Baran _____
Sent: 29 March 2019 12:17
To: Barrett Daliah <Daliah.Barrett@haringey.gov.uk>
Subject: 16-20 High Road, N22 6BX

Dear Daliah,

Im writing this email in regards to the email-s I have received today and yesterday.

Firstly, in regards to public notice; I have forwarded you the picture where the notice is placed. As our entrance is located through this door, at nights we have to close it with a shutter system hence why it was not visible when you visited, going forward I will place the notice on the shutter at nights and then put it back on the window once the shutter is retracted.

The use of (new) upper floor: As we mentioned on the application we will be serving our existing food menu and drinks menu on the new floor. We will serve ancillary shisha to bring a niche to the new floor. Also, as you may know our current diners have to go down to street level (3 large sets of stairs) to smoke their cigarettes, the new floor will also help with this.

I have been in touch with Felicia, asking her input and advice to achieve the 50% along with the help of our chartered architect, we will arrange a meeting to discuss her concerns and no work will be carried out until we have all necessary bureaucracy work in place.

I have already instructed to get a new fire risk assessment report through Falcon Fire to check all means of escape in terms of public safety objective, I will forward the report once its completed.

I hope this help

Thanks

TARSHISH

Baran Yavuz / Director



TARSHISH

Dear Ms Barrett,

I hope this email finds you well.

I write to acknowledge your email dated 24th April 2019 and The Licensing Authority's representation in relation to application for a variation to Tarshish 12 High Road, Wood Green, London N22 6BX.

At this stage we have taken on board the concerns raised regarding the provision of shisha to patrons at Tarshish.

We are abandoning that aspect of that business model. Therefore our application going forward will be for existing restaurant, A3 Al-Fresco Dinning, which, we have planning permission for already.

Turning to the concerns raised on your email dated 3rd April 2019 from Pierre Chenier at 9:29am.

1. *The stairs on the roof plan do not line up with the stairs on the second floor*
2. *No accommodation numbers provided.*
3. *No Call Points shown at Storey exit.*
4. *No emergency lighting shown.*
5. *No exit signage indicated on plan.*
6. *No fire alarm provision indicated.*
7. *Electrical circuits not demonstrated to be fire resisting.*
8. *Electrical circuits not shown to be provided with RCD protection.*
9. *Staircase and balustrading details not provided.*
10. *Provision for disabled not indicated.*

The stairs on the roof plan do not line up with the stairs on the second floor

Attached here is a clarified drawing showing how the relevant stairs line up. We trust this will address the concern raised. (Attachment 1)

No accommodation numbers provided.

We anticipate the maximum number of patrons on the proposed 3rd floor to be 70.



No Call Points shown at Storey exit.

Call Points are clearly addressed please check (Attachment 1)

No emergency lighting shown.

Emergency Lighting is clearly highlighted please see (Attachment 1)

No exit signage indicated on plan.

Exit signage is clearly indicated, please see (Attachment 1)

No fire alarm provision indicated.

Exit signage is clearly indicated, please see (Attachment 1)

Electrical circuits not demonstrated to be fire resisting.

Will be forwarded to Local Authority in due course

Electrical circuits not shown to be provided with RCD protection.

**Electrical circuits are shown on (Attachment 1) but not yet detailed.
You will find this written and displayed on (Attachment 1).
Once detailed will be presented to Local Authority.**

Staircase and balustrading details not provided.

Will be forwarded and illustrated to The Local Authority in due course.

Provision for disabled not indicated.

**Provision for disabled patrons already exists and will be extended to the
proposed 3rd floor.**

**I trust that you will treat this application as a matter of urgency now that
The Local Authorities concerns have been addressed.**

Best Regards

Baran Yavuz



16 – 20 High Road, Wood Green, London, N22 6BX

0m 1m 2m 3m 4m 5m 10m
 (C) The copyright of this drawing is vested with Domus APM and must not be copied or reproduced without written consent.


Fire Legend :

- EL - Emergency Light
- SD - Smoke with Sounder
- CP - Call Point
- Fire Proof Cabling to GF Panel
- FX - Fire Extinguisher

Contractor :

Falcon Electronics Ltd


SEATING CAPACITY = 70



01 Proposed Roof Plan (electrical layout)
 SCALE 1:100 @ A3

Symbol Legend	
[Symbol]	Emergency Light
[Symbol]	Smoke with Sounder
[Symbol]	Call Point
[Symbol]	Fire Extinguisher
[Symbol]	Fire Proof Cabling to GF Panel


<p>CC_003</p>	<p>16-20 High Road Wood Green London N22 6BX</p>	<p>DATE 24/04/19</p> <p>CHECKED BY PC</p> <p>DRAWN BY NK</p>	<p>PROJECT Third floor Extension</p> <p>PROJECT NO. 1901713</p>	<p>CLIENT Tershih Restaurant</p>	<p>DOMUS Architectural & Project Management 16-20 High Road Wood Green London N22 6BX 020 8144 2898</p>
	<p>Approved for construction 24/04/19 PC</p>				



BACK FIRE EXIT

FIRE EXIT FROM 3rd FLOOR PREPARATION

MAIN FIRE EXIT



- Notes**
- 1- This drawing is not for construction
 - 2- All Dimension are in millimeters
 - 3- Dimensions are not to be scaled directly from
 - 4- All dimensions are to be checked on site and the Architect is to be informed of any discrepancies before construction commences
 - 5- All references to drawings refer to current drawings unless otherwise stated
 - 6- The Copyright of this drawing belongs to ArchPI, Ltd.



Rev	Date	Description
BUILDING CONTROL		
ARCH		
ARCHITECTURAL DESIGN STUDIO 13B Grand Parade, Green Lanes, Haringey, London, N4 1LG Tel: 020 8438 0527 Web: www.archpi.co.uk		
Client	Mr Gan Topcu	
Project	Tarshish, 16-20 High Road N22 6BX	
Scale	1/100@A3	Date 08/2017
Drawn By	KD	Checked By HC
Project No.	17063	Drawing No. A102
Revision	-	
Drawing title	Existing Second Floor Plan	

Barrett Daliah

From: Barrett Daliah
Sent: 26 April 2019 11:57
To: 'Baran Yavuz'
Subject: RE: 16-20 High Road, Wood Green, N22 6bx

Hi Baran,

The matters that are outstanding are public safety concerns, so please submit any queries /concerns you or David have by email, once we have an understanding of what these are I will do my best to find time in their diaries for a meeting.

In the meantime I will arrange a Licensing Sub Committee hearing for the matter to be determined.

Regards
Daliah Barrett

From: Baran Yavuz
Sent: 26 April 2019 11:45
To: Barrett Daliah <Daliah.Barrett@haringey.gov.uk>
Subject: 16-20 High Road, Wood Green, N22 6bx

Hi Daliah,

We would like to arrange a meeting to discuss our license around the table. David Dadds will be joining us too.

We are available Wednesday afternoon or Thursday morning.
Looking forward to hear from you.
Regards,

TARSHISH

Baran Yavuz / Director

16-20 High Road, Wood Green
London, N22 6BX

