

Barrett Daliah

Subject: FW: Application for the Variation of a Premises Licence- Tarshish, First & Second Floor, 16-20 High Road, Wood Green, London, N22 6BX(WK/432882)

From: mike.howlin@london-fire.gov.uk <mike.howlin@london-fire.gov.uk>

Sent: 02 April 2019 09:31

To: Barrett Daliah <Daliah.Barrett@haringey.gov.uk>

Subject: RE: Application for the Variation of a Premises Licence- Tarshish, First & Second Floor, 16-20 High Road, Wood Green, London, N22 6BX(WK/432882)

Hi Dale

From the information supplies they do not provide suitable escape as it only shows 2nd and 1st floors with what I assume is main entrance door opening inwards max 60 in whole building and no protection the staircase at 1st floor

Hope that's of help

Regards

Mike Howlin

London Fire Brigade

Barnet, Enfield & Haringey Team

Fire Safety Regulation: North West Area 4

169 Union Street London SE1 0LL

E: FSR-AdminSupport@London-fire.gov.uk

From: Barrett Daliah [<mailto:Daliah.Barrett@haringey.gov.uk>]

Sent: 28 March 2019 17:38

To: HOWLIN, MIKE

Subject: FW: Application for the Variation of a Premises Licence- Tarshish, First & Second Floor, 16-20 High Road, Wood Green, London, N22 6BX(WK/432882)

Hi Mike

Can I flag this one up to you as I think it is a proposed shisha lounge that is being put in place here, any chance you can cast your expert eye over the plans and means of escape.

Thanks

Dale

Barrett Daliah

From: mike.howlin@london-fire.gov.uk
Sent: 26 April 2019 13:19
To: Barrett Daliah
Subject: Revised details for the on for the Variation of a Premises Licence- Tarshish, First & Second Floor, 16-20 High Road, Wood Green, London, N22

Dear Licensing,

VARIATION OF PREMISES LICENSE
Tarshish 16-20 High Rd N22

The Fire Authority, as Responsible Authority under the Licensing Act 2003 with reference to the Licensing objective for the Protection of Public Safety, would like to raise a Representation to the use of the above named premises for the application to vary the Premises License, as shown in the details submitted to this department, for failure to demonstrate compliance

1. The roof area would appear to be a inner room and the means of escape shown is unsatisfactory.
2. It has been stated that the accommodation number is 70, however seating is shown for over 100 people. Two protected exits are required for the new floor level, only one has been indicated therefore the means of escape is unsatisfactory
3. No details of the fire alarm system .
4. No emergency lighting has been shown
5. No exit signage has been indicated on the plan.
6. The provision for disabled access not indicated not clarified

Should you have any queries, please feel free to contact me

Regards

Mike Howlin
London Fire Brigade
Barnet, Enfield & Haringey Team
Fire Safety Regulation: North West Area 4
169 Union Street London SE1 0LL

E: FSR-AdminSupport@London-fire.gov.uk

London Fire Brigade

For advice about how to stay safe from fire and other emergencies, please go to london-fire.gov.uk/Safety

The information in this email may contain confidential or privileged materials. Please read the full email disclaimer notice at london-fire.gov.uk/EmailDisclaimer

The Brigade is committed to using personal data in a responsible and transparent way. To find out more visit london-fire.gov.uk/privacy