

Haringey Licensing Department  
River Park House  
225 High Road  
London  
N22 8HQ

**Your ref:**  
**Our ref** LL001/LL/0000/1109/  
**Date:** 16 March 2022  
**Contact Name:** Mr P Chenier  
**Direct Line:** 020 8489 5136

Dear Sir/Madam

**LICENSING ACT 2003**

**Location: The Cause 15 - 19 Garman Road Tottenham London Haringey N17 0UR**

**Proposal: Premises Licence Application : Music & Dance & Anything similar**

I refer to the above application for a premises License received in this office **11 March 2022**, in respect of the above premises.

The details have been checked for compliance with the requirements of the Regulations and other related legislation. This application has not shown to achieve the minimum standards required under the Technical Standards for Places of Entertainment, as set out in the attached schedule.

The Building Control department, would therefore like to make **Representation**, as Responsible Authority under the Licensing Act 2003, with reference to the Licensing objective for the **Protection of Public Safety**.

Should you wish to discuss this matter further please contact this office.

Yours faithfully



**P. Chenier**  
**Principal Building Surveyor**

Date: 16 March 2022

**LICENSING ACT 2003**

**Location: The Cause 15 - 19 Garman Road Tottenham London Haringey N17 0UR**

**Proposal: Premises Licence Application : Music & Dance & Anything similar**

1. Floors not shown to have a class 0 surface spread of flame.
2. Details of fireproof furnishings not provided.
3. No details of floor coverings and underlays provided to show compliance with British Standard BS5438-1989 and tested to BS 4790 or Class 0.
4. No details provided to demonstrate that all fabrics, curtains, drapes and similar features in the main areas are either be non-combustible or be of durably or inherently flame-retarded fabric.
5. No details provided showing that any fabrics used in escape routes, other than foyers, entertainment areas or function rooms, are non-combustible.
6. No details of Input or output ventilation provided.
7. No heating provision details have been submitted.
8. Details of the electrical installation including cabling type and protection have not been provided. management lighting details have been provided.
9. Insufficient sanitary accommodation shown.