

Haringey Licensing Department
River Park House
225 High Road
London N22 8HQ

Your ref:
Our ref: LL001/LL/0000/1142/
Date: 31 May 2022
Contact Name: Mr P Chenier
Direct Line: 020 8489 5136

Dear Sir/Madam

LICENSING ACT 2003

Location: Channel Lounge 775 High Road Tottenham London Haringey N17 8AH

Proposal: Application for premises Licence Regulated Entertainment: Recorded Music & Anything of a Similar Description to Live Music, Recorded Music & Performance of Dance

I refer to the above application for a premises License received in this office **31 May 2022**, in respect of the above premises.

The details have been checked for compliance with the requirements of the Regulations and other related legislation. This application has not shown to achieve the minimum standards required under the Technical Standards for Places of Entertainment, as set out in the attached schedule.

The Building Control department, would therefore like to make **Representation**, as Responsible Authority under the Licensing Act 2003, with reference to the Licensing objective for the **Protection of Public Safety**.

Should you wish to discuss this matter further please contact this office.

Yours faithfully



P. Chenier
Principal Building Surveyor

Date: 31 May 2022

LICENSING ACT 2003

LIST OF AMENDMENTS TO APPLICATION NO. LL/0000/1142/

1. No accommodation numbers provided.
2. Details of fireproof rating of all furnishings to be provided.
3. Details of floor coverings and underlays to be provided to show compliance with British Standard BS5438-1989 and tested to BS 4790 or Class 0.
4. Details to be provided to demonstrate that all fabrics, curtains, drapes and similar features in the main areas are either be non-combustible or be of durably or inherently flame retardant fabric.
5. Details of Input or output ventilation to be provided.
6. Heating provision details to be been submitted.
7. Details of the electrical installation including cabling type and protection to be provided.
8. Ordinance maps indicate that the kitchen door does not lead to a place of safety and therefore the kitchen is an inner-inner room, the lounge is an inner room and is unsatisfactory.
9. Exit signage and type not shown on plan
10. Locks to exit doors not specified nor associated signage.
11. Call Points not indicated at Storey exit.
12. Emergency lighting points not indicated on plan.
13. Door to Store not shown to be fire doors.
14. Emergency Lighting not shown on plan.
15. Dance/performance area not defined.
16. Provision for disabled not indicated.