

Haringey Licensing Department
River Park House
225 High Road
London N22 8HQ

Your ref:
Our ref LL001/LL/0000/1108/
Date: 11 March 2022
Contact Name: Mr P Chenier
Direct Line: 020 8489 5136

Dear Sir/Madam

LICENSING ACT 2003

Location: Clasic Banquiting hall, 502-508 High Road, London N17

Proposal: Application for premises license - for Live Music, Recorded Music & Performance of Dance

I refer to the above application for a premises License received in this office **11 March 2022**, in respect of the above premises.

You are advised that from our records, there are two outstanding Contravention at this premises for;

- *Formation of cafe and kitchen extension at roof level.* These works appear to constitute the upper area on the plan submitted.
- *Wooden structure has been built to enclose the staircase that is a fire escape.*

The details have been checked for compliance with the requirements of the Regulations and other related legislation. This application has not shown to achieve the minimum standards required under the Technical Standards for Places of Entertainment, as set out in the attached schedule.

The Building Control department, would therefore like to make **Representation**, as Responsible Authority under the Licensing Act 2003, with reference to the Licensing objective for the **Protection of Public Safety**.

Should you wish to discuss this matter further please contact this office.

Yours faithfully



P. Chenier
Principal Building Surveyor



LL001MAUG2021

River Park House
Level 6 - 225 High Road
London N22 8HQ
building.control@haringey.gov.uk
T 020 8489 5504

Date: 11 March 2022

LICENSING ACT 2003

LIST OF AMENDMENTS TO APPLICATION NO. LL/0000/1108/

Location: Clasic Banquiting hall 502-508 High Road, London N17

Proposal: Application for premises license - for Live Music, Recorded Music & Performance of Dance

1. No Operating Schedule provided.
2. No Risk Assessment provided demonstrating an understanding for the potential risks and hazards of the following relevant issues;
 - a. Means of escape
 - b. Fire and other emergency safety and systems
 - c. Building services
 - d. Hygiene and welfare
 - e. Special installations and special effects
 - f. Communications systems
 - g. Ensuring appropriate safe limits on the maximum capacity of the premises