

Haringey Licensing Department  
River Park House  
225 High Road  
London N22 8HQ

**Your ref:**  
**Our ref** LL001/LL/0000/1141/  
**Date:** 31 May 2022  
**Contact Name:** Mr P Chenier  
**Direct Line:** 020 8489 5136

Dear Sir/Madam

**LICENSING ACT 2003**

**Location: Princess Banqueting Hall 502-508 High Road Tottenham London N17**

**Proposal: Application for premises Licence for Live Music, Recorded Music & Performance of Dance**

I refer to the above application for a premises License received in this office **31 May 2022**, in respect of the above premises.

The details have been checked for compliance with the requirements of the Regulations and other related legislation. This application has not shown to achieve the minimum standards required under the Technical Standards for Places of Entertainment, as set out in the attached schedule.

The Building Control department, would therefore like to make **Representation**, as Responsible Authority under the Licensing Act 2003, with reference to the Licensing objective for the **Protection of Public Safety**.

Should you wish to discuss this matter further please contact this office.

Yours faithfully

  
**P. Chenier**  
**Principal Building Surveyor**

Date: 31 May 2022

**LICENSING ACT 2003**

**LIST OF AMENDMENTS TO APPLICATION NO. LL/0000/1141/**

1. No accommodation numbers provided for first or second floor.
2. Clarify if second floor area can be used independently from 1<sup>st</sup> floor area.
3. Details of fireproof rating of all furnishings to be provided.
4. Details of floor coverings and underlays to be provided to show compliance with British Standard BS5438-1989 and tested to BS 4790 or Class 0.
5. Details to be provided to demonstrate that all fabrics, curtains, drapes and similar features in the main areas are either be non-combustible or be of durably or inherently flame retardant fabric.
6. Details of Input or output ventilation to be provided.
7. Heating provision details to be been submitted.
8. Details of the electrical installation including cabling type and protection to be provided.
9. No fire lobby protection provided to the main stair and unsatisfactory.
10. No Exit signage shown to doors onto the main stair.
11. Exit door to the second floor opens in the wrong direction.
12. Locks to exit doors not specified nor associated signage.
13. External exit signage to public highway not indicated.
14. Call Points not indicated at Storey exits.
15. Emergency lighting points not indicated on plan.
16. Clarify use of door adjacent bar on second floor.
17. Access of Kitchen through Store is unsatisfactory.
18. Doors to Stair, Office, Kitchen and Stores not shown to be fire doors.
19. No emergency lighting shown on outside to the public highway.
20. No signage, emergency lighting or fire alarm provision indicated to first floor areas.
21. Emergency Lighting not shown on plan.
22. Dance/performance area not defined.
23. Provision for disabled not indicated.