

Haringey Licensing Department
Alexandra House

10 Station Road,
London
N22 7TR

Date: 03 May 2023
Email: building.control@haringey.gov.uk
Contact No. 020 8489 5504
Your Ref:

Dear Sir/Madam

Licensing Act 2003

Case Reference	LL/2023/0801
Location	Restaurant, 783 High Road, Tottenham, London, N17 8AH
Proposal	Application for a Premises Licence- Stadium Lounge Restaurant & Wine Bar Ltd

I refer to the above application for a premises License received in this office **27 March 2023**, in respect of the above premises.

The details have been checked for compliance with the requirements of the Regulations and other related legislation. This application has not been shown to achieve the minimum standards required under the Technical Standards for Places of Entertainment, as set out in the attached schedule.

The Building Control department, would therefore like to make **Representation**, as Responsible Authority under the Licensing Act 2003, with reference to the Licensing objective for the **Protection of Public Safety**.

Should you wish to discuss this matter further please contact this office.

Yours faithfully

Pierre Chénier
Principal Building Surveyor

LIST OF AMENDMENTS TO APPLICATION

Case Reference	LL/2023/0801
Location	Restaurant, 783 High Road, Tottenham, London, N17 8AH
Proposal	Application for a Premises Licence- Stadium Lounge Restaurant & Wine Bar Ltd

- 1 Accommodation figures not provided. Please clarify the total number of people you wish to have for the License.
- 2 The final exit doors open in the wrong direction and are unsatisfactory.
- 3 Location of Emergency lighting points not shown on Plan(s).
- 4 Full details of the emergency lighting installation to be provided.
- 5 Location of emergency lighting provision to the public highway from the rear exit has not been shown on the plan.
- 6 Location of Fire Alarm & Detection heads not shown on Plan(s).
- 7 Full details of fire alarm system installation to be provided.
- 8 Simple fastenings not specified to all exit doors, i.e., openable on the inside without the use of a key.
- 9 The location of the main electrical intake to be shown on the plan
- 10 Details of Electrical system not provided.
- 11 Details to be provided of the floor wall and ceiling finishes/coverings or underlays have not been provided to demonstrate a minimum British Standard BS5438-1989 and tested to BS 4790 or Class 0.
- 12 Details of input or extract ventilation to be provided for all areas
- 13 Indication of proposed occupancy numbers to be provided to establish the number of required toilets