From: Daliah Barrett On Behalf Of Licensing

Sent: Monday, July 22, 2024 8:39 AM

To: Bruce Burgers <

Subject: FW: Bruces burgers 93 Bruce Grove N17 - ADDITIONAL IMFORMATION FOR

LSC - PUBLIC SAFETY CONCERNS

Dear Sir,

Please be advised that the email below from the officer and the attached pictures will be placed before the Licensing Sub Committee as they provide more information/ insight into the queries raised around means of escape from the rear area.

The plans you have submitted with the application shows the garden area as a sitting /dining area. It does not show that it has a bar area and a separate shisha smoking area in an illegally enclosed space. I have referred the matter to the Planning Department and the Commercial Environmental Heath Team.

A shisha lounge requires planning permission. The structure you have erected in the rear garden requires planning permission. Have you obtained planning permission for any of these matters?

The means of escape through the residential property is not satisfactory and I have referred the matter to the Fire Brigade and other Services.

I must also clarify that at no time since you submitted this application has there been any discussion with you about your customers bringing their own alcohol on the premises, you have misinformed the officer on this point.

Please submit the fire safety risk assessment as a matter of urgency.

Regards

Daliah Barrett

Licensing Team Leader

From: Charlene Thorneycroft <

Sent: Monday, July 22, 2024 12:40 AM

To: Licensing <<u>Licensing@haringey.gov.uk</u>>;

Cc: Jennifer Barrett <

Subject: RE: Bruces burgers 93 Bruce Grove N17

Good evening,

We attended Friday night, there is no rear garden it is an enclosed space with a retractable roof.

The fire exit is behind the bar area which is an extremely narrow walkway, you then have to go up the narrow stairs which looks like into a landing area of a residential premises, down stairs and out through a front door which is not a fire door. (see attached pictures). So, if there as a fire at the front of the premises then you have to come back on yourself through the front door of the premises next door.

We did advise him that should get a proper fire risk assessment carried out and directed him to the London fire brigade website, he said he had paid a company to do one and is awaiting a report to come back for this.

There is access to the kitchen via the rear and the front of the premises but if there was a fire in the kitchen not sure that there would have enough space to accommodate patrons trying to file though the rear fire exit, they have proposed.

I also couldn't see any smoke detectors in the rear area,

In the rear area is another small room, which is fully enclosed and people smoking shisha inside it, will send a smoke free warning letter, they do have a retractable roof but the shisha was in a very small space (see pictures) they may need a visit. This area is on the plans but doesn't say on the plans what the plan for the small enclosed area is going to be used

When we were there the rear area was very busy and they stated that people that were inside brought their own alcohol which he had spoken to Dale about beforehand.

Kind Regards

Charlene Thorneycroft

Noise and Nuisance Officer



9th Floor, Alexandra House 10 Station Road Wood Green, London, N22 7TY

Charlene. Thorneycroft@haringey.gov.uk

www.haringey.gov.uk

twitter@haringeycouncil

facebook.com/haringeycouncil

If you need to report something please log it here: <u>Report It</u> or use our Online Service: <u>Contact Frontline</u> Why wait when you can <u>do it online</u>

Please consider the environment before printing this email.

From: Daliah Barrett < Daliah.Barrett@haringey.gov.uk >

Sent: Tuesday, July 16, 2024 9:28 AM

To: Jennifer Barrett < <u>ASB.Enforcement@haringey.gov.uk</u> **Cc:** Licensing < Licensing.Licensing@haringey.gov.uk>

Subject: Bruces burgers 93 Bruce Grove N17

Hi Jennifer,

Can an officer please visit this premises to obtain pictures of the rear garden area and the means of escape from this location please.

If there was a fire in kitchen how would patrons seated in the back garden get out of the premises.

Thanks

Dale













